

| Information requirements for air-to-air conditioners | | | | | | | | |
|--|---------------|--------|---------------------------------|--|--|--------------|-------|-------------------|
| Model(s):MV6-615WV2GN1-E; Test matching indoor units form, Duct: 4×MI-71T1+4×MI-80T1; | | | | | | | | |
| Outdoor side heat exchanger of air conditioner:air | | | | | | | | |
| Indoor side heat exchanger of air conditioner:air | | | | | | | | |
| Type:compressor driven | | | | | | | | |
| If applicable:driver of compressor:electric motor | | | | | | | | |
| Item | Symbol | Value | Unit | | Item | Symbol | Value | Unit |
| Rated cooling capacity | $P_{rated,c}$ | 61.5 | kW | | Seasonal space cooling energy efficiency | $\eta_{s,c}$ | 198.2 | % |
| Declared cooling capacity for part load at given outdoor temperatures T_j and indoor 27/19°C (dry/wet bulb) | | | | | Declared energy efficiency ratio or gas utilisation efficiency/auxiliary energy factor for part load at given outdoor temperatures T_j | | | |
| $T_j=+35^\circ\text{C}$ | P_{dc} | 61.5 | kW | | $T_j=+35^\circ\text{C}$ | EER_d | 2.79 | -- |
| $T_j=+30^\circ\text{C}$ | P_{dc} | 43.022 | kW | | $T_j=+30^\circ\text{C}$ | EER_d | 3.86 | -- |
| $T_j=+25^\circ\text{C}$ | P_{dc} | 27.726 | kW | | $T_j=+25^\circ\text{C}$ | EER_d | 6.0 | -- |
| $T_j=+20^\circ\text{C}$ | P_{dc} | 12.137 | kW | | $T_j=+20^\circ\text{C}$ | EER_d | 7.65 | -- |
| | | | | | | | | |
| Degradation co-efficient for air conditioners(*) | C_{dc} | 0.25 | — | | | | | |
| Power consumption in modes other than "active mode" | | | | | | | | |
| Off mode | P_{OFF} | 0.064 | kW | | Crankcase heater mode | P_{CK} | 0.064 | kW |
| Thermosat-off mode | P_{TO} | 0 | kW | | Standby mode | P_{SB} | 0.064 | kW |
| Other items | | | | | | | | |
| Capacity control | variable | | | | For air-to-air air conditioner:air flow rate,outdoor measured | — | 17000 | m ³ /h |
| Sound power level,outdoor | L_{WA} | 88 | dB | | | | | |
| GWP of the refrigerant | | 2088 | kg CO ₂ eq(100years) | | | | | |
| Contact details | | | | | | | | |
| (*)If C_{dc} is not determined by measurement then the default degradation coefficient of heat pumps shall be 0.25 | | | | | | | | |
| Where information relates to multi-split air conditioners,the test result and performance data may be obtained on the basis of performance of the outdoor unit ,with a combination of indoor unit(s) recommended by the manufacturer or importer | | | | | | | | |

| Information requirements for heat pumps | | | | | | | | |
|--|---------------|--------|---------------------------------|--|---|--------------|-------|-------------------|
| Model(s):MV6-615WV2GN1-E; Test matching indoor units form, Duct: 4×MI-71T1+4×MI-80T1; | | | | | | | | |
| Outdoor side heat exchanger of air conditioner:air | | | | | | | | |
| Indoor side heat exchanger of air conditioner:air | | | | | | | | |
| Indication if the heater is equipped with a supplementary heater:no | | | | | | | | |
| If applicable:driver of compressor:electric motor | | | | | | | | |
| Parameters shall be declared for the average heating season,parameters for the warmer and colder heating seasons are optional | | | | | | | | |
| Item | Symbol | Value | Unit | | Item | Symbol | Value | Unit |
| Rated heating capacity | $P_{rated,h}$ | 61.5 | kW | | Seasonal space heating energy efficiency | $\eta_{s,h}$ | 133.0 | % |
| Declared heating capacity for part load at indoor teperature 20°C and outdoor temperatures T_j | | | | | Declared coefficient of performance or gas utilisation efficiency/auxiliary energy factor for part load at given outdoor temperatures T_j | | | |
| $T_j=-7^\circ\text{C}$ | P_{dh} | 29.294 | kW | | $T_j=-7^\circ\text{C}$ | COP_d | 2.06 | -- |
| $T_j=+2^\circ\text{C}$ | P_{dh} | 18.293 | kW | | $T_j=+2^\circ\text{C}$ | COP_d | 3.29 | -- |
| $T_j=+7^\circ\text{C}$ | P_{dh} | 11.917 | kW | | $T_j=+7^\circ\text{C}$ | COP_d | 4.80 | -- |
| $T_j=+12^\circ\text{C}$ | P_{dh} | 10.498 | kW | | $T_j=+12^\circ\text{C}$ | COP_d | 5.61 | -- |
| T_{biv} =bivalent temperature | P_{dh} | 29.294 | kW | | T_{biv} =bivalent temperature | COP_d | 2.06 | -- |
| T_{OL} =operation temperature | P_{dh} | 33.107 | kW | | T_{OL} =operation temperature | COP_d | 1.64 | -- |
| Bivalent temperature | T_{biv} | -7 | °C | | | | | |
| | | | | | | | | |
| Degradation co-efficient for heat pumps(**) | C_{dh} | 0.25 | — | | | | | |
| Power consumption in modes other than "active mode" | | | | | Supplementary heater | | | |
| Off mode | P_{OFF} | 0.064 | kW | | Back-up heating capacity(*) | elbu | 0 | kW |
| Thermosat-off mode | P_{TO} | 0.064 | kW | | Type of energy input | | | |
| Crankcase heater mode | P_{CK} | 0.124 | kW | | Standby mode | P_{SB} | 0.064 | kW |
| Other items | | | | | | | | |
| Capacity control | variable | | | | For air-to-air heat pump:air flow rate,outdoor measured | — | 17000 | m ³ /h |
| Sound power level,outdoor | L_{WA} | 88 | dB | | | | | |
| GWP of the refrigerant | | 2088 | kg CO ₂ eq(100years) | | | | | |
| Contact details | | | | | | | | |
| (*) | | | | | | | | |
| (**)If C_{dh} is not determined by measurement then the default degradation coefficient of heat pumps shall be 0.25 | | | | | | | | |
| Where information relates to multi-split heat pumps,the test result and performance data may be obtained on the basis of performance of the outdoor unit ,with a combination of indoor unit(s) recommended by the manufacturer or importer | | | | | | | | |