Cooling mode: Table.7

Information requirements for air-to-air conditioners

Model(s):MV6-400WV2GN1-E; Test matching indoor units form, Duct: 2×MI-56T1+4×MI-71T1;

Outdoor side heat exchanger of air conditioner:air

Indoor side heat exchanger of air conditioner:air

Type:compressor driven

If applicable:driver of compressor:electric motor

Item	Symbol	Value	Unit		Item	Symbol	Value	Unit	
Rated cooling capacity	P _{rated,c}	40	kW		Seasonal space cooling energy efficiency	η _{s,c}	197.8	%	
Declared cooling capacity for part load at given outdoor temperatures $\rm T_{j}$ and indoor 27/19 $^{\circ}\rm C$ $(dry/wet~bulb)$					Declared energy efficiency ratio or gas utilisation efficiency/auxiliary energy factor for part load at given outdoor temperatures T _j				
T _j =+35℃	P _{dc}	40	kW		T _j =+35℃	EER _d	2.65		
T _j =+30℃	P _{dc}	29.504	kW		T _j =+30℃	EER _d	4.11		
T _j =+25℃	P _{dc}	18.187	kW		T _j =+25℃	EER _d	5.86		
T _j =+20℃	P _{dc}	9.939	kW		T _j =+20℃	EER _d	8.72		
Degradation co-efficient for air conditioners(*)	C _{dc}	0.25	-						
		F	Power consumption in	modes of	ther than "active mode"				
Off mode	P _{OFF}	0.064	kW		Crankcase heater mode	P _{CK}	0.064	kW	
Thermosat-off mode	P _{TO}	0	kW		Standby mode	P _{SB}	0.064	kW	
			C	Other item	ns				
Capacity control	variable				For air-to-air air conditioner:air flow rate,outdoor measured	_	13000	m ³ /h	
Sound power level,outdoor	L _{WA}	85	dB						
GWP of the refrigerant		2088	kg CO _{2 eq} (100years)						
		l	L		1				

Contact details

(*)If C_{dc}is not determined by measurement then the default degradation coefficient of heat pumps shall be 0.25

Where information relates to multi-split air conditioners, the test result and performance data may be obtained on the basis of performance of the outdoor unit, with a combination of indoor unit(s) recommended by the manufacturer or importer

Heating mode: Table.8

Information requirements for heat pumps

Model(s):MV6-400WV2GN1-E;

Test matching indoor units form, Duct: 2×MI-56T1+4×MI-71T1;

Outdoor side heat exchanger of air conditioner:air

Indoor side heat exchanger of air conditioner:air

Idication if the heater is equipped with a supplementary heater:no

If applicable:driver of compressor:electric motor

Parameters shall be declared for the average heating season, parameters for the warmer and colder heating seasoms are optional

Parameters shall be decia	ared for the	average nea	iting season,parameters in	or the warmer and colder heating seas	soms are optional				
Item	Symbol	Value	Unit	Item	Symbol	Value	Unit		
Rated heating capacity	P _{rated,h}	40	kW	Seasonal space heating energy efficiency	η _{s,h}	139.0	%		
Declared heating capacity for part load at indoor teperature 20°C and outdoor temperatures T _j				efficiency/auxiliary energy	Declared coefficient of performance or gas utilisation efficiency/auxiliary energy factor for part load at given outdoor temperatures T _j				
T _j =-7°C	P _{dh}	25.931	kW	T _j =-7°C	COP _d	2.54			
T _j =+2℃	P _{dh}	15.791	kW	T _j =+2℃	COP _d	3.36			
T _j =+7℃	P _{dh}	10.318	kW	T _j =+7℃	COP _d	4.66			
T _j =+12℃	P _{dh}	9.548	kW	T _j =+12℃	COP _d	5.49			
T _{biv} =bivalent temperature	P _{dh}	25.931	kW	T _{biv} =bivalent temperature	COP _d	2.54			
T _{OL} =operation temperature	P _{dh}	29.325	kW	T _{OL} =operation temperature	COPd	2.14			
Bivalent temperature	T _{biv}	-7	°C						
Degradation co-efficient for heat pumps(**)	C _{dh}	0.25	-						
Power consumption in mo	odes other	than "active r	node"	Supplementary heater					
Off mode	P _{OFF}	0.064	kW	Back-up heating capacity(*)	elbu	0	kW		
Thermosat-off mode	P _{TO}	0.064	kW	Type of energy input					
Crankcase heater mode	P _{CK}	0.124	kW	Standby mode	P _{SB}	0.064	kW		
			Othe	er items					
Capacity control	variable			For air-to-air heat pump:air flow rate,outdoor measured	_	13000	m³/h		
Sound power level,outdoor	L _{WA}	85	dB						
GWP of the refrigerant		2088	kg CO _{2 eq} (100years)						
Contact details									

(*)

(**)If C_{dh} is not determined by measurement then the default degradation coefficient of heat pumps shall be 0.25

Where information relates to multi-split heat pumps,the test result and performance data may be obtained on the basis of performance of the outdoor unit ,with a combination of indoor unit(s) recommended by the manufacturer or importer